



POSSIBLE ARCHITECTURAL SHAPES:

NO SHAPE MAY EXCEED SIZE OF TESTED RECTANGLE TRANSCRIBED AROUND SHAPE.




JOINT WELD POINTS TYP. (MAY VARY)



TYPICAL ELEVATION

D.L.O. WIDTH = WINDOW WIDTH - 4"
D.L.O. LENGTH = WINDOW LENGTH - 4"



NOTE: WIDTH AND LENGTH DIMENSIONS CAN BE ORIENTED HORIZONTALLY OR VERTICALLY AS SHOWN ABOVE.

ALLOWABLE SIZES & LOADS MAY BE DETERMINED BY INSCRIBING ARCHITECTURAL SHAPES IN SQUARES OR RECTANGLES THAT DO NOT EXCEED SIZES ON PAGES 4/8 & 5/8.

ARCHITECTURAL SHAPES ARE LIMITED TO ± 70 Psf. MAX.

FL#15920.1

ENGINEERING EXPRESS
POSTAL ADDRESS:
2234 NORTH FEDERAL HWY #7664
BOCA RATON, FL 33431
ENGINEERINGEXPRESS.COM

ASSURA WINDOWS & DOORS, LLC
1543 N. POWERLINE RD.
POMPANO BEACH, FL
Phn. (954) 781-4430
SERIES 300 ALUMINUM FIXED WINDOW, LARGE & SMALL
MISSILE IMPACT, FLORIDA BUILDING CODE 8TH ED., (2023)
FLORIDA STATEWIDE APPROVAL (FSA FL#15920.1)

REMARKS	DRWN	CHKD	DATE
FBC 2020(20-32361)	JEM	AP	11/03/20
FBC 2023 UPDATE	AMZ	RS	09/07/23






COPYRIGHT ENGINEERING EXPRESS®

23-66387

SCALE: NTS UNLESS NOTED

02 OF 08

c:\users\ariel\engineering\express\production - documents\projects\23-123-66387 2023 product fbc update fl15920\work\drawings & cad\23-66387a series fixed 300 -fl15920.1 (2023 fsa).dwg



WOOD BUCKS AND METAL STRUCTURE (NOT BY ASSURA) MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.

TYPICAL ANCHORS: SEE ELEV. ON PAGE 2/8 & ANCHOR CHARTS FOR SPACING & QUANTITY

TYPE 'A' - 1/4" DIA. ULTRACON BY 'DEWALT' (Fu=177 KSI, Fy=155 KSI)

THRU 1BY INTO CONCRETE (2846 PSI MIN) OR GROUT FILLED BLOCK (ASTM C90)
1-3/4" MIN. EMBED INTO CONCRETE OR GROUT FILLED BLOCK.

TYPE 'B' - 1/4" DIA. ULTRACON BY 'DEWALT' (Fu=177 KSI, Fy=155 KSI)

INTO 2BY WOOD BUCKS OR WOOD STRUCTURES (SYP#2 G=0.55 MIN)
1-1/2" MIN. PENETRATION INTO WOOD

TYPE 'C' - 1/4-20 DIA. SHEET METAL SCREW (GRADE 5 MIN) (Fu=120 KSI, Fy=90 KSI)

INTO METAL STRUCTURES (5 PINCHES PASS THE THREAD PLANE MIN.) STEEL: 1/8" THK. MIN. (Fy=36 KSI MIN)
ALUMINUM: 1/8" THK. MIN. (6063-T5 MIN)
(STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED)

TYPICAL EDGE DISTANCE
INTO CONCRETE/GROUT FILLED BLOCK= 2-1/2" MIN.
INTO WOOD STRUCTURE = 1" MIN.
INTO METAL STRUCTURE = 3/4" MIN.

1 TYPICAL SECTION
3 6" = 1'-0" VERT SECT

FL#15920.1

ENGINEERING EXPRESS
POSTAL ADDRESS:
2234 NORTH FEDERAL HWY #7664
BOCA RATON, FL 33431
ENGINEERINGEXPRESS.COM

ASSURA WINDOWS & DOORS, LLC
1543 N. POWERLINE RD.
POMPANO BEACH, FL
Phn. (954) 781-4430

SERIES 300 ALUMINUM FIXED WINDOW, LARGE & SMALL
MISSILE IMPACT, FLORIDA BUILDING CODE 8TH ED., (2023)
FLORIDA STATEWIDE APPROVAL (FSA FL#15920.1)

REMARKS	DRWN	CHKD	DATE
FBC 2020(20-32361)	JEM	AP	11/03/20
FBC 2023 UPDATE	AMZ	RS	09/07/23

COPYRIGHT ENGINEERING EXPRESS®

23-66387

SCALE: NTS UNLESS NOTED




03 OF 08

c:\users\ariel\engineering\express\production - documents\projects\23-123-66387 2023 product fbc update fl15920\work\drawings & cad\23-66387a series fixed 300 -fl15920.1 (2023 fsa).dwg

c:\users\arie\engineering\express\production - documents\projects\23-23-66387 2023 product fbc update fl15920\work\drawings & cad\23-66387a series fixed 300 -fl15920.1 (2023 fsa).dwg

FRANK BENNARDO, PE
PE# 0046549 CA# 9885


SEPTEMBER 7, 2023



2 TYPICAL SECTION
4 6" = 1'-0" HORIZ SECT

SCHEDULE "A" FOR SQUARE OR RECTANGLE OPTIONS - OTHER SHAPES ARE LIMITED TO ± 70 Psf (SEE PAGE 2)

FRAME DIMENSION (X)	FRAME DIMENSION (Y)	DESIGN LOAD CAPACITY (ASD METHOD)															
		GLASS TYPE M1		GLASS TYPE M2		GLASS TYPE M3		GLASS TYPE M4		GLASS TYPE M5		GLASS TYPE M6		GLASS TYPE IG1		GLASS TYPE IG2	
		(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.
26"	26 1/2"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	37"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	53 1/8"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	74"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	106 1/4"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
38 3/8"	26 1/2"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	37"	68	68	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	53 1/8"	65	65	70	70	80	80	80	80	80	80	80	130	65	65	80	80
	74"	65	65	70	70	80	80	80	80	80	80	80	130	65	65	80	80
	106 1/4"	-	-	70	70	80	80	80	80	80	80	80	130	-	-	80	80
50 5/8"	26 1/2"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	37"	68	68	70	70	80	80	80	80	80	80	80	130	68	68	80	80
	53 1/8"	49	49	66	66	75	75	80	80	80	80	75	123	49	49	75	75
	74"	-	-	66	66	75	75	80	80	80	80	75	123	-	-	75	75
	106 1/4"	-	-	-	-	-	-	80	80	80	80	75	123	-	-	-	-
63"	26 1/2"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	37"	68	68	70	70	80	80	80	80	80	80	80	130	68	68	80	80
	53 1/8"	47	47	63	63	72	72	80	80	80	80	72	117	47	47	72	72
	74"	-	-	-	-	70	70	76	76	76	76	60	99	-	-	-	-
	106 1/4"	-	-	-	-	70	70	76	76	76	76	-	-	-	-	-	-
74 1/4"	26 1/2"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	37"	68	68	70	70	80	80	80	80	80	80	80	130	68	68	80	80
	53 1/8"	-	-	63	63	72	72	80	80	80	80	72	117	-	-	72	72
	74"	-	-	-	-	69	69	64	64	64	64	51	84	-	-	-	-
	106 1/4"	-	-	-	-	69	69	-	-	-	-	-	-	-	-	-	-
77 1/4"	26 1/2"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	37"	68	68	70	70	80	80	80	80	80	80	80	130	68	68	80	80
	53 1/8"	-	-	63	63	72	72	80	80	80	80	72	117	-	-	72	72
	74"	-	-	-	-	69	69	64	64	64	64	51	84	-	-	-	-
	106 1/4"	-	-	-	-	67	67	-	-	-	-	-	-	-	-	-	-
111 1/4"	-	-	-	-	67	67	-	-	-	-	-	-	-	-	-	-	



EXAMPLE:
A WINDOW WITH A FRAME HEIGHT OF 63" AND FRAME WIDTH OF 53 3/8" HAS AN ALLOWABLE PRESSURE OF +/- 80 PSF FOR GLASS TYPE M4. THESE DIMENSIONS MAY BE REVERSED FOR AN ALLOWABLE FRAME HEIGHT OF 53 3/8" AND AN ALLOWABLE FRAME WIDTH OF 63" FOR THE SAME GLASS TYPE AND ALLOWABLE DESIGN PRESSURE. SEE 80 FOR EXAMPLE VALUE IN SCHEDULE "A."

FL#15920.1

ENGINEERING EXPRESS
POSTAL ADDRESS:
2234 NORTH FEDERAL HWY #7664
BOCA RATON, FL 33431
ENGINEERINGEXPRESS.COM

ASSURA WINDOWS & DOORS, LLC
1543 N. POWERLINE RD.
POMPAHO BEACH, FL
Phn. (954) 781-4430

SERIES 300 ALUMINUM FIXED WINDOW, LARGE & SMALL
MISSILE IMPACT, FLORIDA BUILDING CODE 8TH ED, (2023)
FLORIDA STATEWIDE APPROVAL (FSA FL# 15920.1)

REMARKS	DRWN	CHKD	DATE
FBC 2020 (20-32361)	JEM	AP	11/03/20
FBC 2023 UPDATE	AMZ	RS	09/07/23

23-66387


SCALE: NTS UNLESS NOTED

04 OF 1

c:\users\arie\engineering\express\production - documentos\projects\23-23-66387 2023 product fbc update fl15920\work\drawings & cad\23-66387a series fixed 300 - fl15920-1 (2023 fsa).dwg

FRANK BENNARDO, PE
PE# 0046549 CA# 9885

SEPTEMBER 7, 2023




FOR SQUARE OR RECTANGLE OPTIONS - OTHER SHAPES ARE LIMITED TO ± 70 Psf (SEE PAGE 2)









FRAME DIM (X)	FRAME DIM (Y)	DESIGN LOAD CAPACITY (ASD METHOD)																
		GLASS TYPE M1		GLASS TYPE M2		GLASS TYPE M3		GLASS TYPE M4		GLASS TYPE M5		GLASS TYPE M6		GLASS TYPE IG1		GLASS TYPE IG2		
		(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	
93"	24"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80	
	30"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80	
	36"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80	
	42"	-	-	70	70	80	80	80	80	80	80	80	130	-	-	80	80	
	48"	-	-	70	70	80	80	80	80	80	80	80	130	-	-	80	80	
	54"	-	-	-	-	-	-	-	80	80	80	80	71	115	-	-	-	-
	60"	-	-	-	-	-	-	-	80	80	80	80	64	104	-	-	-	-
	66"	-	-	-	-	-	-	-	72	72	72	72	-	-	-	-	-	-
	72"	-	-	-	-	-	-	-	70	70	66	66	-	-	-	-	-	-
74"	-	-	-	-	-	-	-	69	69	64	64	-	-	-	-	-	-	
96"	24"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80	
	30"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80	
	36"	-	-	70	70	80	80	80	80	80	80	80	130	-	-	80	80	
	42"	-	-	70	70	80	80	80	80	80	80	80	130	-	-	80	80	
	48"	-	-	70	70	80	80	80	80	80	80	80	130	-	-	80	80	
	54"	-	-	-	-	-	-	-	80	80	80	80	71	115	-	-	-	-
	60"	-	-	-	-	-	-	-	80	80	80	80	64	104	-	-	-	-
	66"	-	-	-	-	-	-	-	72	72	72	72	-	-	-	-	-	-
	72"	-	-	-	-	-	-	-	70	70	66	66	-	-	-	-	-	-
74"	-	-	-	-	-	-	-	69	69	64	64	-	-	-	-	-	-	
108"	24"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80	
	30"	60	60	70	70	80	80	80	80	80	80	80	130	60	60	80	80	
	36"	-	-	70	70	80	80	80	80	80	80	80	130	-	-	80	80	
	42"	-	-	61	61	69	69	80	80	80	80	80	130	-	-	69	69	
	48"	-	-	-	-	-	-	80	80	80	80	80	130	-	-	-	-	
	54"	-	-	-	-	-	-	80	80	80	80	80	-	-	-	-	-	
	60"	-	-	-	-	-	-	80	80	80	80	80	-	-	-	-	-	
	66"	-	-	-	-	-	-	-	72	72	72	72	-	-	-	-	-	-
	72"	-	-	-	-	-	-	-	70	70	-	-	-	-	-	-	-	-
74"	-	-	-	-	-	-	-	70	70	-	-	-	-	-	-	-	-	
120"	24"	60	60	70	70	80	80	80	80	80	80	80	130	60	60	80	80	
	30"	-	-	67	67	76	76	80	80	80	80	80	130	-	-	76	76	
	36"	-	-	56	56	64	64	80	80	80	80	80	130	-	-	64	64	
	42"	-	-	-	-	-	-	80	80	80	80	80	130	-	-	-	-	
	48"	-	-	-	-	-	-	80	80	80	80	80	130	-	-	-	-	
	54"	-	-	-	-	-	-	80	80	80	80	80	-	-	-	-	-	
	60"	-	-	-	-	-	-	80	80	80	80	80	-	-	-	-	-	
	66"	-	-	-	-	-	-	-	70	70	-	-	-	-	-	-	-	-
	72"	-	-	-	-	-	-	-	70	70	-	-	-	-	-	-	-	-
74"	-	-	-	-	-	-	-	69	69	-	-	-	-	-	-	-	-	
122"	24"	58	58	70	70	80	80	80	80	80	80	80	130	58	58	80	80	
	30"	-	-	64	64	74	74	80	80	80	80	80	130	-	-	74	62	
	36"	-	-	54	54	62	62	80	80	80	80	80	130	-	-	62	62	
	42"	-	-	-	-	-	-	80	80	80	80	80	130	-	-	-	-	
	48"	-	-	-	-	-	-	80	80	80	80	80	-	-	-	-	-	
	54"	-	-	-	-	-	-	80	80	80	80	-	-	-	-	-	-	
	60"	-	-	-	-	-	-	70	70	-	-	-	-	-	-	-	-	
	66"	-	-	-	-	-	-	70	70	-	-	-	-	-	-	-	-	
	72"	-	-	-	-	-	-	-	70	70	-	-	-	-	-	-	-	-
74"	-	-	-	-	-	-	-	70	70	-	-	-	-	-	-	-	-	
128"	30"	-	-	58	58	67	67	80	80	80	80	80	130	-	-	67	67	
	36"	-	-	49	49	56	56	80	80	80	80	80	130	-	-	56	56	
	42"	-	-	-	-	-	-	80	80	80	80	78	128	-	-	-	-	
	48"	-	-	-	-	-	-	80	80	80	80	-	-	-	-	-	-	
	54"	-	-	-	-	-	-	76	76	74	74	-	-	-	-	-	-	
	60"	-	-	-	-	-	-	70	70	-	-	-	-	-	-	-	-	
	66"	-	-	-	-	-	-	68	68	-	-	-	-	-	-	-	-	
	72"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	74"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
136"	30"	-	-	51	51	59	59	80	80	80	80	80	130	-	-	59	59	
	36"	-	-	-	-	-	-	80	80	80	80	80	130	-	-	-	-	
	42"	-	-	-	-	-	-	80	80	80	80	69	113	-	-	-	-	
	48"	-	-	-	-	-	-	74	74	74	74	-	-	-	-	-	-	
	54"	-	-	-	-	-	-	70	70	-	-	-	-	-	-	-	-	
	60"	-	-	-	-	-	-	65	65	-	-	-	-	-	-	-	-	
	66"	-	-	-	-	-	-	60	60	-	-	-	-	-	-	-	-	
	72"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	74"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
144"	30"	-	-	46	46	52	52	80	80	80	80	80	130	-	-	52	52	
	36"	-	-	-	-	-	-	80	80	80	80	71	116	-	-	-	-	
	42"	-	-	-	-	-	-	74	74	74	74	-	-	-	-	-	-	
	48"	-	-	-	-	-	-	66	66	66	66	-	-	-	-	-	-	
	54"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	60"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	66"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	72"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	74"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

SCHEDULE "B" FOR SQUARE OR RECTANGLE OPTIONS - OTHER SHAPES ARE LIMITED TO ± 70 Psf (SEE PAGE 2)

FRAME DIM (X)	FRAME DIM (Y)	DESIGN LOAD CAPACITY (ASD METHOD)															
		GLASS TYPE M1		GLASS TYPE M2		GLASS TYPE M3		GLASS TYPE M4		GLASS TYPE M5		GLASS TYPE M6		GLASS TYPE IG1		GLASS TYPE IG2	
		(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.	(+) P.S.F.	(-) P.S.F.
36"	24"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	30"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	36"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	42"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	48"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	54"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	60"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	66"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	72"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
48"	24"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	30"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	36"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	42"	60	60	70	70	80	80	80	80	80	80	80	130	60	60	80	80
	48"	52	52	70	70	80	80	80	80	80	80	80	130	52	52	80	80
	54"	52	52	70	70	80	80	80	80	80	80	80	130	52	52	80	80
	60"	52	52	70	70	80	80	80	80	80	80	80	130	52	52	80	80
	66"	52	52	70	70	80	80	80	80	80	80	80	130	52	52	80	80
	72"	-	-	70	70	80	80	80	80	80	80	80	130	-	-	80	80
60"	24"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	30"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	36"	70	70	70	70	80	80	80	80	80	80	80	130	70	70	80	80
	42"	60	60	70	70	80	80	80	80	80	80	80	130	60	60	80	80
	48"	52	52	70	70	80	80										



GLASS TYPES



MATERIAL SCHEDULE

ITEM	PART	DESCRIPTION	MATERIAL	MANUF./SUPPLIER/REMARKS
1	N3001	0.063" SILL/JAMB/HEADER EXTRUSION	6063-T6	
2	TM-326	1/8" GLASS STOP FOR 1" GLASS	6063-T6	
3	TM-327	1/8" GLASS STOP FOR 9/16" GLASS	6063-T6	
4	-	0.050" SNAP COVER	6063-T6	
5	-	0.370" HIGH D VINYL BULB AND 0.187" T-SLOT	TPE POLYPROPYLENE FOR 5/16" GLASS	ULTRAFAB
6	32001	VINYL BULB - 0.175"Ø	INSULATED GLASS GLAZING BEAD	AMESBURY
7	32011	VINYL BULB - 0.270"Ø	7/16 AND 9/16 GLASS GLAZING BEAD	AMESBURY
8	-	(2) #8 X 1 SMS SCREWS AT EACH FRAME CORNER SAE GR 2 MIN	FOR RECTANGULAR WINDOW SHAPES ONLY	
9	-	SEAM SEALER	ACRYLIC	SCHNEE-MOREHEAD
10	-	-	-	
11	-	SETTING BLOCK 1" LONG AT 1/4 POINTS	HIGH DENSITY RUBBER 70-90 SHORE A DUROMETER HARDNESS	
12	-	OPTIONAL SURFACE APPLIED MUNTINS	6063-T6	
13	-	RAPID STRENGTH RGS7700 STRUCTURAL SILICONE	ELASTOMETRIC ADHESIVE	BY MOMENTIVE PERFORMANCE MATERIALS
14	-	ALUMINUM "U" CHANNEL 2" LONG AT EVERY ANCHOR LOCATION (TYP.)	5052 H32 ALUMINUM	
15	-	5/16" XL EDGE GLASS SPACER	STAINLESS STEEL	ALL METAL
16	-	7/16" XL EDGE GLASS SPACER	STAINLESS STEEL	ALL METAL
17	-	PRIMARY SEAL	PIB	
18	-	SECONDARY SEAL	SILICONE	

FL#15920.1

ENGINEERING EXPRESS
 POSTAL ADDRESS:
 2234 NORTH FEDERAL HWY #7664
 BOCA RATON, FL 33431
 ENGINEERINGEXPRESS.COM

ASSURA WINDOWS & DOORS, LLC
 1543 N. POWERLINE RD.
 POMPANO BEACH, FL
 Phn. (954) 781-4430

SERIES 300 ALUMINUM FIXED WINDOW, LARGE & SMALL
 MISSILE IMPACT, FLORIDA BUILDING CODE 8TH ED. (2023)
 FLORIDA STATEWIDE APPROVAL (FSA FL#15920.1)

REMARKS	DATE	DRWN	CHKD
FBC 2020 (20-32361)	11/03/20	JEM	AP
FBC 2023 UPDATE	09/07/23	AMZ	RS

COPYRIGHT ENGINEERING EXPRESS®

23-66387

SCALE: NTS UNLESS NOTED

06

c:\users\ariel\engineering\express\production - documents\projects\23-23-66387 2023 product fbc update fl15920\work\drawings & cad\23-66387a series fixed 300 -fl15920.1 (2023 fsa).dwg

